



Supporting Steel Frame: The supporting steel framework (columns and beams) of the mezzanine floor should be fire protected for a period equal or greater to that required of the mezzanine floor ceiling. This may be achieved using VERMICULUX® or PROMATECT® 250. For details on the requirements for protecting structural steelwork, refer to the Promat Fire Protection Handbook.

Flooring: Minimum 18mm T&G boarding or flooring grade chipboard (1), fastened at each joist using minimum 30mm x No.8 self-drilling, self-tapping screws at maximum 300mm centres (2 fixings per board at each joist position in the case of T&G boarding).

Joists: Cold rolled steel joists (2) at maximum 600mm centres. The in-house fire tests on which this recommendation is based involved cold rolled joist sections in the range 120mm deep x 1.5mm gauge thickness and 260mm deep x 3.2mm gauge section. These represent the typical sizes likely to be encountered in mezzanine floors. For cold rolled joists outside this range, consult with Promat Technical Services Department.

Fillet Strip: 12mm SUPALUX®, 100mm wide (3), fastened under all steel joists using 25mm x No.8 self-drilling, self-tapping screws (4) at 600mm centres.

Ceiling: 12mm SUPALUX® boards (5), fastened with 35mm x No.8 self-drilling, self-tapping screws (6), at 300mm centres.

Infill: Mineral wool (7), minimum 60mm thick x 23kg/m³. Mineral wool must not overlap the flanges of the joists.

NB: The joist sizes and centres, together with the flooring thickness and grade, must be determined for the required span, point and distributed load of the mezzanine floor.

AUTHORITY: Promat Recommendation

Technical Data
Sheet – 019

Page 1 of 1
(Dec 2003)



Promat UK Limited
Technical Services Department
The Sterling Centre, Eastern Road
Bracknell, Berkshire RG12 2TD
Tel: 01344 381 400
Fax: 01344 381 401
E-mail: technicaluk@promat.co.uk

